

**UOBWA AWIA Risk and Resilience Assessment RFP**  
**Answers to Questions**

08.19.20

**Q:** Will UOBWA accept proposals from IT consulting firms for the cybersecurity assessment portion of the AWIA Risk and Resilience Assessment/Emergency Response Plan only?

**A:** No, proposals must be submitted and stamped by a certified civil engineer.

08.19.20

**Q:** Because there is no “engineering” or “design” work involved in the AWIA process, would UOBWA / NGRC consider setting aside this requirement?

**A:** No, the requirement will remain, and reports must be stamped by a GA Licensed Engineer.

08.21.20

**Q:**

1. Can you provide the population served by the UOBWA including populations of wholesale customers?

**A:** UOBWA serves four wholesale customers. Wholesale customer population sizes may be found by querying the EPA Water System ID (WSID) database here: <https://www.epa.gov/enviro/sdwis-search>

2. Does the UOBWA maintain a distribution system? ~~No. If yes please provide the following:~~
  - ~~a. Approximately how many miles of distribution mains are maintained?~~
  - ~~b. How many storage tanks are maintained?~~
  - ~~c. How many booster pump stations?~~
  - ~~d. How many pressure zones are in the system?~~

3. How many treatment plants are in operation?

**A:** One

4. How many source water withdrawal permits does the Authority have?

**A:**

<b>List of Georgia EPD UOBWA Surface Water Withdrawal Permits (Revised April 2018)</b>						
<b>River Basin</b>	<b>Surface Water Withdrawal Permit Holder</b>	<b>Surface Water Withdrawal Permit Number</b>	<b>County</b>	<b>Source</b>	<b>Permit Limit Max Day (Million Gallons/Day)</b>	<b>Permit Limit Monthly Average (Million Gallons/Day)</b>
Oconee	Upper Oconee Basin Water Authority	<b>078-0304-06</b>	Jackson	Bear Creek Reservoir	79.000	58.000
Oconee	Upper Oconee Basin Water Authority	<b>078-0304-05</b>	Jackson	Middle Oconee River	60.000	60.000

09.10.20

Q: Does the water authority already have an ERP or will the Consultant be required to prepare one from scratch? If one exists, can we assume the water authority would be able to provide it in MS Word form for us to amend?

A: Yes. UOBWA had an ERP prepared in March 2015. It is available in PDF format.